**PWSID** ME0091660

WISCASSET WATER DISTRICT

**2015 Consumer Confidence Report**

## General Information

**Water System Contact Name:** Chris W. Cossette, Superintendent

**Address:** Wiscasset Water District, 65 Birch Point Road

**City, State, Zip Code:** Wiscasset, Maine 04578

**Telephone #:** 207-882-6402 **Fax#:** 207-882-5958 **Email:** wiscwater@myfairpoint.net

**Report Covering Calendar Year:** Jan 1 - Dec 31, 2015

**Upcoming Regularly Scheduled Meeting(s):** 3rd Monday of every month

## Source Water Information

**Description of Water Source:** Consecutive Connections: 1 (Cons Conn - Bath Water District)

**Water Treatment & Filtration Information:** Bath Water District, Nequasset Lake Treatment Facility

**Source Water Assessment:**

The sources of drinking water include rivers, lakes, ponds, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material and can pick up substances resulting from human or animal activity. The Maine Drinking Water Program (DWP) has evaluated all public water supplies as part of the Source Water Assessment Program (SWAP). The assessments included geology, hydrology, land uses, water testing information, and the extent of land ownership or protection by local ordinance to see how likely our drinking water source is to being contaminated by human activities in the future. Assessment results are available at town offices, public water suppliers, and the DWP. For more information about the SWAP, please contact the DWP at telephone 287-2070.

## Water Test Results

| *Contaminant* | *Date* | *Results* | *MCL* | *MCLG* | *Source* |
|---|---|---|---|---|---|
| **Microbiological** | | | | | |
| COLIFORM (TCR) (1) | 2015 | **0 pos** | 1 pos/mo or 5% | 0 pos | Naturally present in the environment. |
| **Lead/Copper** | | | | | |
| COPPER 90TH% VALUE (3) | 1/1/2014 - 12/31/2016 | **0.15 ppm** | AL = 1.3 ppm | 1.3 ppm | Corrosion of household plumbing systems. |
| LEAD 90TH% VALUE (3) | 1/1/2014 - 12/31/2016 | **3 ppb** | AL = 15 ppb | 0 ppb | Corrosion of household plumbing systems. |
| **Disinfectants and Disinfection Byproducts** | | | | | |
| **ENTRY POINT** | | | | | |
| TOTAL HALOACETIC ACIDS (HAA5) (7) | LRAA(2015) | **25 ppb Range (17–35 ppb)** | 60 ppb | 0 ppb | By-product of drinking water chlorination. |
| TOTAL TRIHALOMETHANE (TTHM) (7) | LRAA(2015) | **26 ppb Range (10.8–35.8 ppb)** | 80 ppb | 0 ppb | By-product of drinking water chlorination. |

**Definitions:**

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water.
Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health.
Running Annual Average (RAA): A 12 month rolling average of all monthly or quarterly samples at all locations. Calculation of the RAA may contain data from the previous year.
Locational Running Annual Average (LRAA): A 12 month rolling average of all monthly or quarterly samples at specific sampling locations. Calculation of the RAA may contain data from the previous year.

Action Level (AL): The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.
Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

**Units:**

ppm = parts per million or milligrams per liter (mg/L).
ppb = parts per billion or micrograms per liter (µg/L).
pCi/L = picocuries per liter (a measure of radioactivity).
pos = positive samples.
MFL = million fibers per liter

**Notes:**

1) Total Coliform Bacteria: Reported as the highest monthly number of positive samples, for water systems that take less than 40 samples per month.
2) Fluoride: For those systems that fluoridate, fluoride levels must be maintained between 0.5 to 1.2 ppm. The optimum level is 0.7 ppm.
3) Lead/Copper: Action levels (AL) are measured at consumer's tap. 90% of the tests must be equal to or below the action level.
4) Nitrate: Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health provider.
5) Gross Alpha: Action level over 5 pCi/L requires testing for Radium 226 and 228. Action level over 15 pCi/L requires testing for Uranium. Compliance is based on Gross Alpha results minus Uranium results = Net Gross Alpha.
6) Radon: The State of Maine adopted a Maximum Exposure Guideline (MEG) for Radon in drinking water at 4000 pCi/L, effective 1/1/07. If Radon exceeds the MEG in water, treatment is recommended. It is also advisable to test indoor air for Radon.
7) TTHM/HAA5: Total Trihalomethanes and Haloacetic Acids (TTHM and HAA5) are formed as a by-product of drinking water chlorination. This chemical reaction occurs when chlorine combines with naturally occurring organic matter in water. Compliance is based on running annual average.

**All other regulated drinking water contaminants were below detection levels.**

## Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Contaminants that may be present in source water include:

**Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

**Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

**Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

**Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and can also come from gas stations, urban runoff, and septic systems.

**Radioactive Contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing.

Wiscasset Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at: **http://www.epa.gov/safewater/lead**

## Violations

**No Violations in 2015**

## Waiver Information (to be included in the CCR for systems that were granted a waiver)

**No Water Testing Waivers in 2015**